LIST OF D. P. W. SUBJECTS.

KADUR DISTRICT.

Subject and speaker	Summary of discussion	Reply of Govt.
Subject No. 222 **Chikmagalur water works. Mr. C. Srinivasa Rao, and Mr. B. Gundappa, of Chikmagalur Municipality**	(*a*) Owing to the impounding reservoir being out of order, water is supplied to the town by pipes without being filtered. Till the impounding reservoir is restored, temporary arrangements may be made for the supply of filtered water. (*b*) The reservoir has been always under repair. The stone work of the bund is constantly slipping, and as soon as one portion is repaired, another requires rebuilding. The filter tank was built with only a wall which is in an unsafe condition. It is suggested that a channel be cut from the present Ramdev Anikat to feed the filter tanks. This will enable the town being supplied with water from an unfailing source while the wet lands of Kalledevarapura, Byagadahalli and Allampur will not be thrown out of cultivation. As the Municipality has incurred a very large expenditure on account of the water works and is in consequence heavily in debt, it is requested that the cost of repairs and establishment may not be charged to the Municipality.	Under consideration in the Public Works Department and will be expedited.
Subject No. 223 **Transfer of certain roads to Provincial Funds.** **Mr. M. Ganesha Rao of Kadur District Fund Board.**	The Kalsa-Kotigehar and Kalsa-Balehonnur roads should be transferred from District Funds to Provincial Funds and the necessary improvements made.	Such transfers are being gradually effected with due reference to the situation & character of the roads. The present proposal will receive consideration in the Public Works Department.
Subject No 224 **Feeding of certain tanks with water from Tirthahalla. Mr, Attiganal Shamanna and Mr. Nandi Abdul Khader of Tarikere Taluk.**	In compliance with repeated representations already made Tirthahalla may be utilized as a feeder to Nagannanakere, Sundahallikere, Ramanayakanakere and other tanks below, for the benefit of both the raiyats and Government. This project may either be taken in hand by Gov-	The Public Works Department is investigating this project and will come to an early decision.

Subject and speaker	Summary of discussion	Reply of Govt.
	ern ment at once, or permitted to be under-taken by private individuals in which latter case, the increase of wet and garden assessment resulting therefrom should be given over to them.	
Subject No 225 (a) Opening a road through the bed of Dalavaikere tank. Mr. Attiganal Shamanna and Mr. Nandi Abdul Khader of Tarikere Taluk.	Though Rs. 1,000 was contributed five years ago by the people for the opening of a road from Tarikere through the bed of Dalavaikere tank and leading to coffee estates and Government jungles, nothing has as yet been done in the matter. If this is undertaken and opened out up to Holeyrayanahalla, it will facilitate the transport of timber to Tarikere Depôt and traffic to and from coffee gardens.	Public Works Department will expedite.
(b) The Bababudan road to be joined on to the Santaweri road.	The present extension of the Bababudan road, instead of being joined on to Lingadahalli road, may be connected with the Santaweri road near Kenchapur *via* Nandibatlu.	
Subject No. 226 Restoration of Hale Madag tank. Mr. P. Ranganna and Mr. A. Ranga Rao of Kadur Taluk.	The Hale Madag tank which has fallen into disrepair should be restored.	The question is before Government in the Public Works Department.
Subject No. 227 Restoration of Turvanhalli tank Mr. P. Rangauna, and Mr. A. Ranga Rao of Kadur Taluk.	For the restoration of the Turvanahalli tank, the Public Works Department demand payment in one lump sum of a contribution of Rs. 5,000. This the raiyats are not able to pay. They are however willing to pay the same by five annual instalments of Rs. 1,000. This may be accepted and the work undertaken.	Referred to the Public Works Department for consideration.
Subject No. 228 Repairs to the Tangali Anikat. Mr. P. Ranganna and Mr. A. Ranga Rao of Kadur Taluk.	The breach in the Tangali Anikat has not been filled up, in spite of frequent representations. Early steps may be taken to fill in the breach.	All that can possibly be done is being done by the Public Works Department to prevent leakage.